Process Control Equipment for Use in Class I, Zone 0, 1 and 2 Hazardous Locations Certified for Canada

See General Information for Process Control Equipment for Use in Class I, Zone 0, 1 and 2 Hazardous Locations Certified for Canada

G M INTERNATIONAL S R L E222308
VIA SAN FIORANO 70
20058 VILLASANTA MI, ITALY

Associated apparatus, nonhazardous locations.

Digital input isolators, Models D1030D, D1030S, D1032D, D1032Q may or may not be followed by B, Model D1130D; Signal converter isolator Model D1053S may or may not be followed by B; Temperature converter isolator Model D1073S may or may not be followed by B, associated apparatus for use in nonhazardous locations, Ex [ia]. Provides intrinsically safe circuits for use in Class I, Zone 0, Group IIC Hazardous Locations when connected in accordance with data sheets plus safety and installation instructions DTS0020/ISM0008, DTS0148/ISM0041, DTS0173/ISM0048, DTS0041/ISM0016 and DTS0043/ISM0019 as shown on the specific markings for each isolator.

Associated apparatus; Class I, Zone 2, Groups IIC; Class I, Division 2, Groups A, B, C and D hazardous locations.

Digital input isolators, Models D1031D, D1031Q, D1033D, D1033Q may or may not be followed by B; Digital output isolators Models D1040Q, D1041Q, D1042Q, D1043Q may or may not be followed by B Analog input isolators, Models D1010D and D1010S may or may not be followed by B; Analog output isolators, Models D1020D and D1020S may or may not be followed by B; Signal converter isolators, Models D1052D, D1052S, D1052X and D1060S may or may not be followed by B; Temperature converter isolators Models D1072D, D1072S and D1072X may or may not be followed by B; Power supply isolators, Models PSD1001 and PSD1001C may or may not be followed by B, for use in Class I, Zone 2, Ex nA or nC [ia] IIC Hazardous Locations. Provides intrinsically safe circuits for use in Class I, Zone 0, Group IIC Hazardous Locations when connected in accordance with data sheets plus safety and installation instructions DTS0023/ISM0009, DTS0151/ISM0043, DTS0038/ISM0020, DTS0016/ISM0007, DTS0017/ISM0012, DTS0040/ISM0015, DTS0162/ISM0054, DTS0025/ISM0018, DTS0145/ISM0023 and DTS0187/ISM0065 as shown on the specific markings for each isolator.

Last Updated on 2004-04-09

This page and all contents are Copyright © 2005 by Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2005 Underwriters Laboratories Inc.®"

Process Control Equipment for Use in Hazardous Locations Certified for Canada

See General Information for Process Control Equipment for Use in Hazardous Locations Certified for Canada

G M INTERNATIONAL S R L E222308
VIA SAN FIORANO 70
20058 VILLASANTA MI, ITALY

Associated apparatus, nonhazardous locations.

Digital input isolators, Models D1030D, D1030S, D1032D, D1032Q may or may not be followed by B, Model D1130D; Signal converter isolator Model D1053S may or may not be followed by B; Temperature converter isolator Model D1073S may or may not be followed by B, associated apparatus for use in nonhazardous locations. Provides intrinsically safe circuits for use in Class I, Division 1, Groups A, B, C and D; Class II, Division 1, Groups E, F and G Hazardous Locations when connected in accordance with data sheets plus safety and installation instructions DTS0020/ISM0008, DTS0148/ISM0041, DTS0173/ISM0048, DTS0041/ISM0016 and DTS0043/ISM0019 as shown on the specific markings for each isolator.

Associated apparatus; Class I, Zone 2, Groups IIC; Class I, Division 2, Groups A, B, C and D hazardous locations.

Digital input isolators, Models D1031D, D1031Q, D1033D, D1033Q may or may not be followed by B; Digital output isolators Models D1040Q, D1041Q, D1042Q, D1043Q may or may not be followed by B; Analog input isolators, Models D1010D and D1010S may or may not be followed by B; Analog output isolators, Models D1020D and D1020S may or may not be followed by B; Signal converter isolators, Models D1052D, D1052S, D1052X and D1060S may or may not be followed by B; Temperature converter isolators Models D1072D, D1072S and D1072X may or may not be followed by B; Power supply isolators, Models PSD1001 and PSD1001C for use in Class I, Division 2, Groups A, B, C and D; Hazardous Locations. Provides intrinsically safe circuits for use in Class I, Division 1, Groups A, B, C and D; Class II, Division 1, Groups E, F and G Hazardous Locations when connected in accordance with data sheets plus safety and installation instructions DTS0023/ISM0009, DTS0151/ISM0043, DTS0038/ISM0020, DTS0016/ISM0007, DTS0017/ISM0012, DTS0040/ISM0015, DTS0162/ISM0054, DTS0025/ISM0018, DTS0145/ISM0023 and DTS0187/ISM0065, as shown on the specific markings for each isolator.

Last Updated on 2004-04-09

This page and all contents are Copyright © 2005 by Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2005 Underwriters Laboratories Inc.®"

Process Control Equipment for Use in Class I, Zone 0, 1 and 2 Hazardous Locations

See General Information for Process Control Equipment for Use in Class I, Zone 0, 1 and 2 Hazardous Locations

G M INTERNATIONAL S R L E222308
VIA SAN FIORANO 70
20058 VILLASANTA MI, ITALY

Associated apparatus, nonhazardous locations.

Digital input isolators, Models D1030D, D1030S, D1032D, D1032Q may or may not be followed by B, Model D1130D; Signal converter isolator Model D1053S may or may not be followed by B; Temperature converter isolator Model D1073S may or may not be followed by B, associated apparatus for use in nonhazardous locations, AEx [ia]. Provides intrinsically safe circuits for use in Class I, Zone 0, Group IIC Hazardous Locations when connected in accordance with data sheets plus safety and installation instructions DTS0020/ISM0008, DTS0148/ISM0041, DTS0173/ISM0048, DTS0041/ISM0016 and DTS0043/ISM0019 as shown on the specific markings for each isolator.

Associated apparatus; Class I, Zone 2, Groups IIC; Class I, Division 2, Groups A, B, C and D hazardous locations.

Digital input isolators, Models D1031D, D1031Q, D1033D, D1033Q may or may not be followed by B; Analog input isolators, Models D1010D and D1010S may or may not be followed by B; Analog output isolators, Models D1020D and D1020S may or may not be followed by B; Signal converter isolators, Models D1052D, D1052S, D1052X and D1060S may or may not be followed by B; Temperature converter isolators Models D1072D, D1072S and D1072X may or may not be followed by B; Power supply isolators, Models PSD1001 and PSD1001C may or may not be followed by B, Digital output isolators Models D1040Q, D1041Q, D1042Q, D1043Q may or may not be followed by B for use in Class I, Zone 2, AEx nA or nC [ia] IIC Hazardous Locations. Provides intrinsically safe circuits for use in Class I, Zone 0, Group IIC Hazardous Locations when connected in accordance with data sheets plus safety and installation instructions DTS0023/ISM0009, DTS0151/ISM0043, DTS0038/ISM0020 DTS0016/ISM0007, DTS0017/ISM0012, DTS0040/ISM0015, DTS0162/ISM0054, DTS0025/ISM0018, DTS0145/ISM0023 and DTS0187/ISM0065, as shown on the specific markings for each isolator.

Last Updated on 2004-04-09

This page and all contents are Copyright © 2005 by Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2005 Underwriters Laboratories Inc.®"

Process Control Equipment for Use in Hazardous Locations

See General Information for Process Control Equipment for Use in Hazardous Locations

G M INTERNATIONAL S R L E222308
VIA SAN FIORANO 70
20058 VILLASANTA MI, ITALY

Associated apparatus, nonhazardous locations.

Digital input isolators, Models D1030D, D1030S, D1032D, D1032Q may or may not be followed by B, Model D1130D; Signal converter isolator Model D1053S may or may not be followed by B; Temperature converter isolator Model D1073S may or may not be followed by B, associated apparatus for use in nonhazardous locations. Provides intrinsically safe circuits for use in Class I, Division 1, Groups A, B, C and D; Class II, Division 1, Groups E, F and G Hazardous Locations when connected in accordance with data sheets plus safety and installation instructions DTS0020/ISM0008, DTS0148/ISM0041 DTS0173/ISM0048, DTS0041/ISM0016 and DTS0043/ISM0019 as shown on the specific markings for each isolator.

Associated apparatus; Class I, Zone 2, Groups IIC; Class I, Division 2, Groups A, B, C and D hazardous locations.

Digital input isolators, Models D1031D, D1031Q, D1033D, D1033Q may or may not be followed by B; Digital output isolators Models D1040Q, D1041Q, D1042Q, D1043Q may or may not be followed by B; Analog input isolators, Models D1010D and D1010S may or may not be followed by B; Analog output isolators, Models D1020D and D1020S may or may not be followed by B; Signal converter isolators, Models D1052D, D1052S, D1052X and D1060S may or may not be followed by B; Temperature converter isolators Models D1072D, D1072S and D1072X may or may not be followed by B; Power supply isolators, Models PSD1001 and PSD1001C for use in Class I, Division 2, Groups A, B, C and D; Hazardous Locations. Provides intrinsically safe circuits for use in Class I, Division 1, Groups A, B, C and D; Class II, Division 1, Groups E, F and G Hazardous Locations when connected in accordance with data sheets plus safety and installation instructions DTS0023/ISM0009, DTS0151/ISM0043, DTS0038/ISM0020, DTS0016/ISM0007, DTS0017/ISM0012, DTS0040/ISM0015, DTS0162/ISM0054, DTS0025/ISM0018, DTS0145/ISM0023 and DTS0187/ISM0065, as shown on the specific markings for each isolator.

Last Updated on 2004-04-09

This page and all contents are Copyright © 2005 by Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2005 Underwriters Laboratories Inc.®"